



State Water Resources Control Board

Division of Drinking Water

July 20, 2017

System No. 0310004

Mr. Jeff Gardner, City Manager City of Plymouth P.O. Box 429 Plymouth, CA 95669

TRANSMITTAL OF CITATION NO. 01_10_17C_014 FOR FAILURE TO COLLECT ROUTINE BACTERIOLOGICAL SAMPLES (JUNE 2017)

Dear Mr. Gardner,

The City of Plymouth (hereinafter "City") Water System (System No. 0310004) failed to collect both routine bacteriological samples during the month of June 2017, as specified in Chapter 15, Title 22, California Code of Regulations. The State Water Resources Control Board, Division of Drinking Water has issued Citation No. 01_10_17C_014, in response to this violation. The Citation is being transmitted to the City under cover of this letter.

Any person who is aggrieved by an order or decision issued by the deputy director of the Division of Drinking Water under Article 8 (commencing with Health and Safety Code section 116625) or Article 9 (commencing with Health and Safety Code section 116650), of the Safe Drinking Water Act (Chapter 4, Part 12, Division 104, of the Health and Safety Code) may file a petition with the State Water Board for reconsideration of the order or decision. Petitions must be received by the State Board within 30 days of the issuance of the order or decision by the Deputy Director. The date of issuance is the date when the Division of Drinking Water mails a copy of the order or decision. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m.

Please respond to the Directives of this Citation by the deadlines established with each item. If you have any questions regarding this Citation, please contact Brian Kidwell by email at Brian.Kidwell@waterboards.ca.gov, or by phone at (209) 948-3963.

Sincerely,

Bhupinder S. Sahota, P.E.

District Engineer, Stockton District NORTHERN CALIFORNIA BRANCH DRINKING WATER FIELD OPERATIONS

Attachments:

Citation No. 01 10 17C 014

Certified Mail No. 7004 2890 0002 0057 9911

R:\DDW\Stockton\Dist10-Staff\BKidwell\Water Systems\0310004 - Plymouth\Enforcement\Citations

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

1	STATE OF CALIFORNIA		
2	WATER RESOURCES CONTROL BOARD		
3	DIVISION OF DRINKING WATER		
4			
5	TO: City of Plymouth		
6	P.O. Box 429		
7	Plymouth, CA 95669		
8			
9	Attn: Mr. Jeff Gardner, City Manager		
10	City of Plymouth		
11			
12	CITATION FOR VIOLATION OF CALIFORNIA CODE OF REGULATIONS,		
13	TITLE 22, SECTION 64423(a)(1)		
14	WATER SYSTEM NO. 0310004		
15	CITATION NO. 01_10_17C_014		
16	Issued on July 20, 2017		
17			
18	Section 116650 of the California Health and Safety Code authorizes the issuance of		
19	a citation to a public water system for violation of the California Safe Drinking Water		
20	Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with		
21	Section 116270) (hereinafter "California SDWA"), or any regulation, standard, permi		
22	or order issued or adopted thereunder.		
23			
24	The State Water Resources Control Board (hereinafter "Board"), acting by and		
25	through its Division of Drinking Water (hereinafter "Division") and the Deputy Director		
26	for the Division (hereinafter "Deputy Director"), hereby issues a citation to the City of		



1	Plymouth (hereinafter, "City") (P.O. Box 429 Plymouth, CA 95669) for violation of
2	California Code of Regulations (CCR), Title 22, Section 64423 subsection (a)(1).
3	
4	APPLICABLE AUTHORITIES
5	Section 116650 of California Health and Safety Code provides:
6	
7	(a) If the Division determines that a public water system is in violation of this chapter
8	or any regulation, permit, standard, citation, or order issued or adopted thereunder,
9	the Division may issue a citation to the public water system. The citation shall be
10	served upon the public water system personally or by certified mail. Service shall be
11	deemed effective as of the date of personal service or the date of receipt of the
12	certified mail. If a person to whom a citation is directed refuses to accept delivery of
13	the certified mail, the date of service shall be deemed to be the date of mailing.
14	
15	(b) Each citation shall be in writing and shall describe the nature of the violation or
16	violations, including a reference to the statutory provision, standard, order, citation,
17	permit, or regulation alleged to have been violated.
18	
19	(c) A citation may specify a date for elimination or correction of the condition
20	constituting the violation.
21	
22	(d) A citation may include the assessment of a penalty as specified in subdivision (e).
23	
24	(e) The Division may assess a penalty in an amount not to exceed one thousand
25	dollars (\$1,000) per day for each day that a violation occurred, and for each day that a
26	violation continues to occur. A separate penalty may be assessed for each violation.



CITATION NO. 01_10_17C_014 Issued: July 20, 2017 California Code of Regulations, Title 22, Section 64423, subsection (a)(1) provides, in relevant part:

(a) Each water supplier shall collect routine bacteriological water samples as follows:

(1) The minimum number of samples for community water systems shall be based on the known population served or the total number of service connections, whichever results in the greater number of samples, as shown in Table 64423-A.

Table 64423-A
Minimum Number of Routine Total Coliform Samples

Monthly Population Served	Service Connections	Minimum Number of Samples
25 to 1000	15 to 400	1 per month
1,001 to 2,500	401 to 890	2 per month
2,501 to 3,300	891 to 1,180	3 per month
3,301 to 4,100	1,181 to 1,460	4 per month
4,101 to 4,900	1,461 to 1,750	5 per month
4,901 to 5,800	1,751 to 2,100	6 per month
5,801 to 6,700	2,101 to 2,400	7 per month
6,701 to 7,600	2,401 to 2,700	2 per week
7,601 to 12,900	2,701 to 4,600	3 per week
12,901 to 17,200	4,601 to 6,100	4 per week
17,201 to 21,500	6,101 to 7,700	5 per week
21,501 to 25,000	7,701 to 8,900	6 per week
25,001 to 33,000	8,901 to 11,800	8 per week

STATEMENT OF FACTS

The City water system is operated under Water Supply Permit No. 03-10-95P-007, which was issued on December 12, 1995.

The City water system is publically owned and operated. The City is located in Amador County, on California Highway 49, just south of Placerville. The service area is approximately one square mile in size. The water system is classified as a community water system that serves primarily residential customers living within the



CITATION NO. 01_10_17C_014 Issued: July 20, 2017

	I and the second
1	City's service area. The water system serves approximately 1,060 people through
2	480 service connections.
3	
4	Purchased treated surface water is obtained from the Amador Water Agency's Tanner
5	Plant. The purchased treated water is re-chlorinated and stored in a 500,000-gallon
6	water storage tank. The distribution system is maintained as two pressure zones and
7	is gravity fed from the storage tank. Pressure reducing valves are located throughout
8	the water system.
9	
10	According to Table 64423-A of the California Code of Regulations and the City's
11	approved Bacteriological Sample Siting Plan, dated May 2016, two routine samples
12	are to be collected and analyzed for total coliform bacteria on a monthly basis. On
13	July 13, 2017, the Division was notified, via a phone call from Andrea Hinton, from the
14	Amador Water Agency, that only one of the required routine bacteriological samples
15	was collected during June 2017.
16	
17	DETERMINATION
18	The Division has determined that the City failed to comply with the requirements of
19	Section 64423(a)(1) due to the fact that the City failed to collect the required routine
20	bacteriological samples for the month of June 2017.
21	
22	<u>DIRECTIVES</u>
23	The City is hereby directed to take the following actions:
24	
25	1. The City shall collect six (6) routine bacteriological samples during July 2017.
26	These results shall be reported to the Division by August 10, 2017.



CITATION NO. 01_10_17C_014 Issued: July 20, 2017

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

2. By August 10, 2017, the City shall submit a plan which includes details to ensure the water system does not miss future routine bacteriological monitoring. The plan should also include the time of the month the routine bacteriological samples will be taken. It should be noted that choosing a sampling date in the beginning of the month may reduce the risk of missing monthly bacteriological monitoring. If samples are missed at the beginning of the month, the City would have ample time to collect the required sample later the same month.

The above mentioned plan shall also include details about improving the communication between the City and the Division. In the future, if required bacteriological samples are missed, the City should contact the Division in a timely manner.

- 3. Notify the consumers served by the City of the missed routine bacteriological sample in conformance with Section 64463.4, Title 22, CCR. The notification shall be provided in accordance with the following:
 - a. Provide written notice of the missed routine bacteriological sample to all residents, via hand delivery or mail, and post notification in public places served by the water system. The notification shall be hand delivered or mailed and posted in public places no later than August 10, 2017. The posted notice shall remain posted for at least 7 days.
 - b. A sample notification form that can be used to satisfy the notification requirement is attached to this Citation. Within ten (10) days of supplying the written notification and posting of the written notification,

1	the City shall submit to the Division a copy of the notification, including
2	certification of its delivery.
3	
4	The Division reserves the right to make such modifications to this Citation as it may
5	deem necessary to protect public health and safety. Such modifications may be
6	issued as amendments to this Citation, and shall be deemed effective upon issuance.
7	
8	Nothing in this Citation relieves the City of its obligation to meet the requirements of
9	the California Safe Drinking Water Act, or of any regulation, permit, standard, or order
10	issued or adopted thereunder.
11	
12	All submittals required by this Citation shall be submitted to the Division, via electronic
13	delivery, at the following address:
14	
15 16	Brian.Kidwell@waterboards.ca.gov
17	PARTIES BOUND
18	This Citation shall apply to and be binding upon the City, its officers, directors,
19	shareholders, agents, employees, contractors, successors, and assignees.
20	
21	SEVERABILITY
22	The Directives of this Citation are severable, and the City shall comply with each and
23	every provision thereof, notwithstanding the effectiveness of any other provision.
24	
25	FURTHER ENFORCEMENT ACTION
26	The California SDWA authorizes the Board to: issue citation with assessment of
27	administrative penalties to a public water system for violation or continued violation of



the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with violates an order of the Board. The Board does not waive any further enforcement action by issuance of this citation.

10

11

13

14

15

16

1

2

3

4

5

6

7

8

9

12

Bhupinder S. Sahota, P.E.,

District Engineer, Stockton District

Division of Drinking Water

State Water Resources Control Board

17

18

19

20 21

22 23 24

Attachments:

- 1. Public Notification
- 2. Proof of Notification Form

Certified Mail No. 7004 2890 0002 0057 9911

R:\DDW\Stockton\Dist10\Stockton System Files\03 Alpine-Amador County\0310004\Enforcement\Citations



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.

Tradúzcalo o hable con alguien que lo entienda bien.

Monitoring Requirements Not Met for [System]

Our water system failed to monitor as required for drinking water standards during the past year and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During [compliance period dates], we ['did not monitor or test' or 'did not complete all monitoring or testing'] for [contaminant(s)] and therefore, cannot be sure of the quality of our drinking water during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during the
 last year, how many samples we are required to take and how often, how many
 samples we took, when samples should have been taken, and the date on which
 follow-up samples were (or will be) taken.

Contaminant	Required Sampling Frequency	Number of Samples Taken	When All Samples Should Have Been Taken	When Samples Were or Will Be Taken
	[number] sample every [number][time interval]			
,	·			

 If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

[Describe corrective action].

For more information, please contact [name of contact] at [phone number] or [mailing address].

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by [system].				
	State Water System ID#:	Date distributed:		

Drinking Water Notification to Consumers

PROOF OF NOTIFICATION

Name of Water System:					
	Please explain what caused the problem if you have determined what it was and what steps you have taken to correct it.				
Consur	mers Notified	Yes	No		
If not, E	Explain:				
Date of	Notification:				
	date of notification set forth consumers by:	above, I served the above	ve referenced document(s)		
	Sending a copy through the U.S. Mail, first class, postage prepaid, address to each of the resident(s) at the place where the property is situated, pursuate the California Civil Code. Attach copy of Notice.				
	Newspaper (if the problem	has been corrected). Att	ach a copy of Notice.		
	Personally hand-delivering a copy to each of the consumers. Attach a copy o Notice.				
		•	by each of the consumers ior Department approval).		
hereb	y declare the forgoing to be	true and correct under	penalty of perjury.		
Dated:_	MARCON II.				
	·	Signature of Person	Serving Notice		

**Notice: Complete this Proof of Notification and return it <u>along with a copy of the</u> <u>notification</u> to the Department within <u>10 days</u> of giving public notice.

Disclosure: Be advised that the California Health and Safety Code states that any person who knowingly makes a false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by fine of not more than twenty-five thousand dollars (\$25,000) for each day of violation, or be imprisoned in county jall not to exceed one year or by both the fine and Imprisonment.